

**NOTES:**

1. ALL EXPOSED PIPING AND FITTINGS SHALL BE GALVANIZED WITH EXCEPTION OF STORZ CONNECTION
2. PIPE MATERIAL SHALL BE CLASS 350 DIP AWWA C150 AND C151 APPROVED BY THE TOWN. PIPE MATERIAL BEHIND THE BACKFLOW PREVENTER SHALL MEET NC PLUMBING CODE TABLE 605.4
3. PROPERTY OWNER SHALL BE RESPONSIBLE FOR MAINTENANCE AND OPERATION OF FDC AND ACCESSORIES
4. 50' MAX DISTANCE FROM FDC TO APPARATUS - FIRE HYDRANT
5. FOR NFPA 13R SYSTEMS (2 1/2" RISER AND SMALLER) SINGLE FDC WITH NATIONAL STANDARD THREADS SHALL BE USED
6. AN APPROVED CONNECTION (TAPPING IS NOT APPROVED)

