



**NOTES:**

1. TRANSVERSE EXPANSION JOINTS SHALL BE SPACED 50' MAXIMUM.
2. CONTRACTION JOINTS SHALL BE SPACED 5' MAXIMUM.
3. ALL CONCRETE TO BE FINISHED WITH CURING COMPOUND.
4. ALL CONCRETE SHALL CONFORM TO ALL APPLICABLE REQUIREMENTS OF THE ACI.
5. SIDEWALK EASEMENT REQUIRED WHEN SIDEWALK IS OUTSIDE PUBLIC RIGHT OF WAY.