



NOTE:

1. TRACER WIRE AND ACCESSORIES SHALL BE BLUE FOR WATER INSTALLATIONS AND GREEN FOR WASTEWATER INSTALLATIONS.
2. TEST STATIONS SHALL BE 2.5" DIAMETER WITH 2 TERMINALS, GREEN OR BLUE TOP AND BE EQUIVALENT TO BINGHAM AND TAYLOR MODEL P-225SR OR COPPERHEAD MODEL LD12TP AND SHALL BE INSTALLED IN A TOWN STANDARD VALVE BOX PER STANDARD DETAIL.