



NOTES:

1. THIS DETAIL SHALL APPLY ONLY TO TEMPORARY CAPPING. PERMANENT DEAD END LINES TO BE IN ACCORDANCE WITH THE STANDARD BLOWOFF DETAIL.
2. REQUIRED RESTRAINT AWAY FROM THE DEAD END MAY BE MJ PIPE WITH WEDGE ACTION RESTRAINTS FOR PIPE \leq 12 INCH DIAMETER.