



NOTES:

1. PUMP STATION PROPERTY OR EASEMENT SHALL BE 50' x 50' (ft.) MINIMUM.
2. EQUIPMENT LOCATIONS AND DIMENSIONS MAY VARY.
3. SITE WITHIN FENCE SHALL BE 5 INCH THICK REINFORCED CONCRETE SLAB OR 3 INCHES CRUSHED STONE OVER GEOTEXTILE FABRIC (SPECIFIED BY DIRECTOR OF WATER RESOURCES).
4. THE PUMP STATION SITE LAYOUT AND DESIGN SHALL MEET ALL TOWN OF APEX SITE PLANNING AND DESIGN REQUIREMENTS.
5. PIGGING & BYPASS CONNECTION LOCATION WILL VARY.
6. BYPASS PUMPING CONNECTION SHALL BE LOCATED SO THAT IT IS NOT IN CONFLICT WITH GATE, ENTRY OF VEHICLES, OR ACCESS OTHER STATION COMPONENTS.

TOWN OF APEX
STANDARDS

EFFECTIVE: MARCH 23, 2021

TYPICAL PUMP STATION LAYOUT < 500 gpm

STD. NO.

800.09

SHEET 1 OF 1