



NOTES:

1. ALL VALVE BOXES AND COVERS SHALL MEET ASTM A48, GRADE 35B IRON REQUIREMENTS.
2. IN CASES WHERE MAX. VALVE BOX HEIGHT IS EXCEEDED, USE 6" DIP AS A PROTECTIVE SLEEVE AND INCLUDE A VALVE NUT EXTENSION.
3. IF THE VALVE OPERATING NUT IS GREATER THAN 6 FEET FROM THE SURFACE AN EXTENSION KIT FROM THE VALVE MANUFACTURER MUST BE PROVIDED.