



**NOTES:**

1. THERE SHALL BE NO MULTIPLE CONNECTIONS FOR SERVICES OTHER THAN 3/4" AND 1" (FOR RESIDENTIAL ONLY).
2. GATE VALVE REQUIRED ON SERVICE LINE 2" OR GREATER.
3. CURB STOPS SHALL BE AS MANUFACTURED BY FORD OR APPROVED EQUAL.
4. METER BOXES SHALL BE AS DESCRIBED IN THE STANDARD SPECIFICATIONS UNDER WATER DISTRIBUTION; HOWEVER, THE INLET SHALL BE IRON PIPE THREADED INLETS.
5. CURB STOPS SHALL BE CENTERED ON MULTIPLE BRANCH SERVICE AND CONTAINED WITHIN A VALVE BOX.