



IN-LINE WYE FITTING OR APPROVED TAPPING SADDLE PROVIDED AT TOP QUARTER OF THE MAIN

IN-LINE WYE REQUIRED FOR SANITARY SEWER SERVICES INSTALLED WITH NEW CONSTRUCTION WHEN PARCEL AND SERVICE LOCATIONS ARE KNOWN AND IDENTIFIED ON APPROVED PLANS

DEPTH ≤ 16 FEET - CLASS "A" BEDDING

- UNDERCUT TRENCH BOTTOM 6 INCHES MINIMUM BELOW PIPE
- FILL PIPE TO SPRING LINE WITH NO. 57 OR 67 STONE

DEPTH > 16 FEET - CLASS "B" BEDDING

- UNDERCUT TRENCH BOTTOM 6 INCHES MINIMUM BELOW PIPE
- FILL TO 6 INCHES ABOVE PIPE WITH NO. 57 OR 67 STONE

INSTALLATIONS THAT EXCEED 20 FEET DEPTH SHALL BE DIP

TOWN OF APEX
STANDARDS

EFFECTIVE: APRIL 12, 2022

SANITARY SEWER TAP & SERVICE

STD. NO.

700.02

SHEET 1 OF 1