

NOTES:

1. PIPING CONFIGURATION TO BE USED ON ALL DROPS EXCEEDING 24".
2. DROPS TO BE CONSTRUCTED OF A.B.S. OR P.V.C. PIPE.
3. PIPING CONFIGURATION TO BE INSTALLED WITHIN 3" OF MANHOLE WALL.
4. SERVICE LINE MAY NOT ENTER MANHOLE THROUGH CONE SECTION OR ANY JOINT.
5. STAINLESS STEEL STRAPPING SHALL BE 1" WIDE BY 1/8" THICK AND ATTACHED TO THE MANHOLE WALL WITH MASONRY ANCHORS.

