



NOTES:

1. CONCRETE SHALL BE 3000 P.S.I.
2. CONCRETE ENCASEMENT NOT REQUIRED WHEN PIPE IS AT LEAST 3 FEET UNDER CENTERLINE OF CREEK BOTTOM.

TOWN OF APEX
STANDARDS

EFFECTIVE: DECEMBER 21, 2010

CONCRETE ENCASEMENT FOR STREAM CROSSING

STD. NO.

700.15

SHEET 1 OF 1